Design Guidelines

Section 5
Communication Cabling.

Contents

5.1 _____

5.2 _____

5.3 _____

5.4 _____

5.5 _____

5.1 Overview

5.2 Design Concepts

5.2.1 Cabling Structure

The structured cabling system shall comprise the following nine subsystems (SS):

- SS1 - Campus distributor
- SS2 - Building distributor
- SS3 - Backbone cabling
- SS4 - Floor distributor
- SS5 - Telecommunications room
- SS6 - Horizontal cabling
- SS7 - Consolidation point
- SS8 - Work area
- SS9 - Telecommunications outlet

5.3 Systems and Equipment

The fibre solution shall utilise Standard single-mode optical fibre (OS2) optical fibre cabling of Emtelle Fibreflow ¥ or similar microcable fibre unit consisting of 6, 8 or 12 fibres in compliance with ITU-T G.652 D Series.

compliant and provide the same amount of protection as the aforementioned products. A sample of the alternative product shall be included with any submission.

Penetrations

A minimum of 40% spare capacity for additional cable is to be allowed for all projects.

The Contractor shall effectively seal and fire stop to the appropriate level all openings (made or provided) in, or through, building walls, floors, etc. after cable reticulation.

Fire protection installed in penetrations shall be easily removable without causing damage to cabling, and must not in any way restrict future use of the penetration. In general, RTV type sealants must not be used on penetrations intended to hold spare capacity unless measures are in place to allow selective removal. Use of re-openable fire gaskets or intumescent pillows is the preferred solution.

The Contractor shall effectively seal all cable duct openings above ground level, and all cable entries into trenches in buildings to prevent the ingress of moisture and the entry of rodents.

The Contractor shall ensure that all spare conduit and cable entries into equipment are effectively plugged and sealed to prevent the ingress of moisture, dust, rodents and insects.

The Contractor shall ensure that all openings through roofs and external walls are made weather proof including the installation of flashing and/or rain hoods to prevent the entry of driving rain, seepage, etc.

Allowance for future Cabling

In addition to the minimum space capacity in penetrations and on cable tray, allowances must be made for access to cable trays at all corners, penetrations and a minimum of every 10 metres along tray runs. Catenary wires should be accessible along the length of the wire.

Painting and Corros ion Protection

The contractor shall be responsible for corrosion protection

5.4 Installation Requirements

5.4 Numbering & Labelling